

7835.5600 VARYING VOLTAGE LEVELS.

The qualifying facility must be operated so that variations from acceptable voltage levels and other service-impairing disturbances do not adversely affect the service or equipment of other customers, and so that the facility does not produce levels of harmonics which exceed the prescribed limits of commission rules or other levels customarily accepted.

Statutory Authority: *MS s 216A.05; 216B.08; 216B.164*

History: *9 SR 993*

Published Electronically: *February 28, 2000*